



\* COMMERCIAL BUILDINGS ARE REQUIRED TO HAVE EITHER A DOUBLE CHECK VALVE (WATTS 007 OR SIMILAR), OR A REDUCED PRESSURE ZONE ASSEMBLY (WATTS 009 OR SIMILAR), DEPENDING ON BUILDING USE.  
 THE CPWA WILL DETERMINE WHICH DEVICE WILL BE REQUIRED FOR EACH APPLICATION.

STANDARD DETAIL FOR WATER SYSTEM INSTALLATION  
 COMMERCIAL WITH IRRIGATION

CLIFTON PARK WATER AUTHORITY  
 661 CLIFTON PARK CENTER RD,  
 CLIFTON PARK, NY 12065

